



# USED GENERATOR TECHNICAL DATA SHEET

## Generating Set Information

Stock No	YG0474	
Genset Manufacturer	FG Wilson	
Genset Model	P675	
Manuf Serial No	C4831A/001	
Year of Manufacture	1997	
Hours Run	180	
Prime Rating	0675	0540



## Engine and Alternator Information

Engine Manuf	Perkins	Alternator Manuf	Leroy Somer
Engine Model	3012TAG2	Alternator Model	
Engine Serial No		Alternator Serial No	
Engine Configuration	12 Cylinder VEE formation		

## Ratings

Amps	<input type="text"/>	Volts	<input type="text" value="400"/>	Phase	<input type="text" value="3"/>	PF	<input type="text" value="0.8"/>	Hz	<input type="text" value="50"/>	RPM	<input type="text" value="1500"/>
------	----------------------	-------	----------------------------------	-------	--------------------------------	----	----------------------------------	----	---------------------------------	-----	-----------------------------------

## General Information

FG Wilson 750 KVA standby rated unit in as new condition - only 175 hours from new

## Control Panel

Set mounted auto start

## Additional Information

Type Of Unit	
Length	
Width	
Height	
Approx Weight	

All our machines are serviced and fully tested prior to sale.  
Customer witness testing is welcomed at our premises,  
contact our office to make prior arrangements

**Price : £29,950.00 nett ex-works UK**

**Tel : +44 (0) 1430 850001**

**Fax : +44 (0) 1430 850002**

**eMail : mail@yellogen.com**

**www : www.yellogen.com**

**24 OROORY HILL  
DROMORE CO DOWN  
NORTH IRELAND BT25 1LE**