



# USED GENERATOR TECHNICAL DATA SHEET

## Generating Set Information

Stock No	YG0477	
Genset Manufacturer	Cummins	
Genset Model	C250	
Manuf Serial No	Conf. D093243GX02	
Year of Manufacture	1977	
Hours Run	630	
Prime Rating	0250	200



## Engine and Alternator Information

Engine Manuf	Cummins	Alternator Manuf	Stamford Newage
Engine Model	NTA855G	Alternator Model	C534B
Engine Serial No	23143619	Alternator Serial No	D2746
Engine Configuration	6 Cylinder inline water cooled turbocharged diesel		

## Ratings

Amps	361	Volts	400/231	Phase	3	PF	0.8	Hz	50	RPM	1500
------	-----	-------	---------	-------	---	----	-----	----	----	-----	------

## General Information

Ex Standby unit only 630 hours from new.

Unit is self contained with saddle mounted fuel tank, set mounted control panel and set mounted circuit breaker

## Control Panel

Deep Sea Electronics (DSE) 7110 fully digital auto start module with full engine and alternator monitoring and protections

## Additional Information

Type Of Unit	OPEN
Length	
Width	
Height	
Approx Weight	

All our machines are serviced and fully tested prior to sale.  
Customer witness testing is welcomed at our premises,  
contact our office to make prior arrangements

**Price : £7,500.00 nett ex-works UK**

**Tel : +44 (0) 1430 850001**

**Fax : +44 (0) 1430 850002**

**eMail : mail@yellogen.com**

**www : www.yellogen.com**

**BLenheim ROAD  
POCKLINGTON IND EST  
YORK, YO42 1NR**